

The City of Olean, NY is seeking proposals from qualified ground water contractors to clean and repair/redevelop our Well Site 38M. A problem has surfaced with fine particles causing unacceptable turbidity levels whenever the well is shut down and restarted. This has occurred after routine well redevelopment projects in the past. We do not know what is causing the problem and are asking for proposals to attempt to fix the problem.

Well Data:

| | |
|-------------------------------------|--|
| Well ID: | 38M |
| Type: | Packed Gravel |
| Pump: | Submersible, 20HP motor |
| Rated GPM: | 753 GPM |
| Well Casing: | 18" (begins 9' 4" from top of pitless) |
| Upper Casing: | 20" Baker Monitor Pitless |
| Total Depth from top of 20" casing: | 79.1' |
| Screen: | 15.0', Layne Stainless Steel Shutter |
| Pump Suction Inlet: | Approximately 63' from top of pitless |

The following items are required as part of this proposal.

1. This project is subject to NYS Prevailing Wage requirements. Documentation is attached to this proposal outlining the requirements of work performed in Cattaraugus County, NY.
2. The following personnel must be involved in the project:
 - a. A qualified drilling superintendent who is registered as by the NGWA as a certified well driller per NYSDEC requirements. This person shall also have at least five (5) years of experience in water well cleaning and redevelopment.
 - b. A qualified hydrogeologist/geologist with experience in ground water flow system, well and well field design, and well development. Contractor is to submit the resume of said person with the proposal.
 - c. If a crane is to be utilized in this project, the crane operator must be a NYS Certified Crane Operator by the NYS Department of Labor.
3. The following insurance requirements must be met and proof submitted to the City of Olean with the proposal.

Prior to award of contract, the successful bidder shall supply copies of insurance certificates as follows:

A) Insurance covering claims under workers compensation, disability benefit and other similar employee benefit acts, against himself/herself or any of them, or by anyone whose acts any of them may be liable.

B) Contractor's Protective Liability Insurance.

| | |
|---|-------------|
| Each Occurrence | \$1,000,000 |
| Damage to Rented Premises (each occurrence) | \$1,000,000 |
| Medical Expense (any one person) | \$1,000,000 |
| Personal & Adv. Injury | \$1,000,000 |
| General Aggregate | \$2,000,000 |
| Products – Comp/Op Agg | \$2,000,000 |

C) Automobile Liability Insurance:

| | |
|---------------------------------------|-------------|
| Combined Single Limit (each accident) | \$1,000,000 |
|---------------------------------------|-------------|

D) Excess/Umbrella Liability:

| | |
|-----------------|-------------|
| Each Occurrence | \$5,000,000 |
| Aggregate | \$5,000,000 |

E) Worker's Compensation and Employer's Liability

| | |
|------------------------------|------------|
| E.L. Each Accident | \$ 100,000 |
| E.L. Disease – Each Employee | \$ 100,000 |
| E.L. Disease – Policy Limit | \$ 500,000 |

4. This proposal shall be quoted as "NOT TO EXCEED"
5. In addition to the actual proposal, a non-collusion statement (attached) must accompany the proposal.
6. **Unless agreed upon by both the City of Olean and the contractor, work shall be completed by no later than December 2, 2016.**

REQUIRED RESULTS:

Upon completion of the project, the City of Olean requires that:

1. The well can be stopped and restarted in 1-2 hours with a maximum turbidity spike of no more than 2.0 NTU. The second well at the site (37M) is able to easily meet these standards. It will be deactivated during the tests so as to not affect the results from 38M
2. Well yield shall not be negatively affected. The well must be able to produce at least 700 gpm of clean water upon completion of the project (The well was redeveloped in the fall of 2015, and this flow was met and exceeded at that time.)
3. If, during the project, the contractor finds a problem that needs corrected and is outside the scope of their bid, they are to immediately notify the City of Olean and provide a cost estimate for said repairs. It is the sole discretion of the City of Olean whether to authorize such repairs.

Please Send Bids to:

**City of Olean
Water Filtration Plant
1332 River Street
Olean, NY 14760**

(RE: Well 38M REPAIR Project)

Attach a signed copy of the non-collusion statement that follows.

**Proposals must be received by the City of Olean no later than
Friday, Sept. 16, 2016**

CONTACT INFORMATION:

**Dale Walker, Senior Operator
City of Olean Water Plant
1332 River Street
Olean, NY 14760**

(716) 376-5699 or dwalker@cityofolean.org

Required Documentation to be attached

- 1. Bid Proposal and Quote**
- 2. Non-Collusion Statement**
- 3. Safety Data Sheets for all chemicals to be used**
- 4. Proof of Insurance**
- 5. Hydrogeologist/Geologist Resume**
- 6. NYS DEC Well Driller Certification**
- 7. Statement of Experience in Well Rehabilitation**

BID PROPOSAL FOR CITY OF OLEAN WATER
DIVISION
WELL REHABILITATION PROJECT.

AUTHORIZED SIGNATURE: _____

OFFICIAL TITLE _____

BIDDER'S NAME: _____

ADDRESS: _____

TELEPHONE NUMBER: _____

DATED: _____

EMAIL: _____

BID DEADLINE: Friday, Sept. 16, 2016

QUOTE FOR PROJECT COST:

Well Site 18M Rehabilitation Cost:

(NOT TO EXCEED)

The City of Olean is tax-exempt. Tax ID# available upon request.

NON-COLLUSIVE BIDDING CERTIFICATION

BY SUBMISSION OF THIS BID OR PROPOSAL, THE BIDDER CERTIFIES THAT:

- [1] This bid or proposal has been independently arrived at without collusion with any other bidder or with any competitor or potential competitor.
- [2] This bid or proposal has not been knowingly disclosed and will not be knowingly disclosed, prior to the opening of bids or proposals for this project, to any other bidder, competitor or potential competitor.
- [3] No attempt has been or will be made to include any other person, partnership or corporation to submit or not to submit a bid or proposal.
- [4] The person signing this bid or proposal certifies that he fully informed himself regarding the accuracy of the statements contained in this certification, and under the penalties of perjury, affirms the truth thereof, such penalties being applicable to the bidder as well as to the person signing in its behalf,

BIDDER

BY: _____

DATED: _____